Artesian Water Company
Sussex County Stand-Alone Water Systems

STAND-ALONE WATER SYSTEM	NUMBER OF CUSTOMERS	DISTRIBUTION SYSTEM	NO. OF WELLS	DNREC WELLFIELD ALLOCATION	TREATMENT	STORAGE	BACK-UP POWER
Beaver Creek (includes service to Shoreview Woods and Holland Mills)	292	42,400 Feet of Water Main and 42 Fire Hydrants	2	414,500 gpd	Chlorine, Caustic, Phosphate, Ion Exchange (Iron Removal)	132,000 Gallon Ground Storage Tank	Yes
Cedar Landing	108	8,546 Feet of Water Main	2	Less than 50,000 gpd	Chlorine, Phosphate, Ion Exchange (Iron Removal)	Hydro-Pneumatic Tanks	Yes
Ingram Village	2	4,400 Feet of Water Main	-	One residential well was drilled to provide service to the first three homes.	No treatment required for a residential well.	Hydro-Pneumatic Tanks	No