Artesian Water Company
New Castle County Stand-Alone Water Systems

STAND-ALONE WATER SYSTEM	NUMBER OF CUSTOMERS	DISTRIBUTION SYSTEM	NO. OF WELLS	DNREC WELLFIELD ALLOCATION	TREATMENT	STORAGE	BACK-UP POWER
Delaware Correctional Center (DCC)	4 Master Meters	15,000 Feet of Water Main and 12 Fire Hydrants	4	2,131,000 gpd	Chlorine	300,000 Gallon Elevated Storage	Well #3
Bayview	43	1,790 Feet of Water Main	3	430,000 gpd	Chlorine, Phosphate, Iron Removal	Hydro-Pneumatic Tanks	Yes
Commodore Estates	47	6,614 Feet of Water Main and 5 Fire Hydrants	2	430,000 gpd	Chlorine, Phosphate, Iron Removal	Hydro-Pneumatic Tanks	Yes
Augustine Creek	203	18,938 Feet of Water Main and 20 Fire Hydrants	3	124,000 gpd	Chlorine, Phosphate, Potassium Permanganate, Iron Removal	88,000 Gallon Ground Storage Tank	Yes
Odessa Woods	12	1,440 Feet of Water Main	2	Less than 50,000 gpd	Chlorine, Phosphate	Hydro-Pneumatic Tanks	Yes